



Government of West Bengal
Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services
First Floor of Duragapur Fire Station, Durgapur City Centre, P.O.:- Durgapur, P.S.:- Durgapur, Pin:- 713216

Memo No.: FSR/FES/BDN/ 945/2016

Date : 29-03-2025

From :
Divisional Fire Officer
Paschim Bardhaman,
West Bengal Fire & Emergency Services

To :
DAV PUBLIC SCHOOL KANYAPUR ASANSOL
Opposite to D.M. Office, Lions Club Road, PO.-R.K. Mission, Mouza-Gobindpur, Plot No-395, Khatian No-75, J.L. No.-18, PS.-Asansol(N), Pin.-713305, Dist.-Paschim Bardhaman under Asansol Municipality Corporation.

Sub : Renewal of Fire Safety Certificate for existing construction of G+2 storied Phase-I building, G+3 storied Phase-II building and G+3 storied Phase-III building under group Educational occupancy in the name and style as DAV PUBLIC SCHOOL KANYAPUR ASANSOL at Lions Club Road, PO.-R.K. Mission, Mouza-Gobindpur, Plot No-395, Khatian No-75, J.L. No.-18, PS.-Asansol(N), Pin.-713305, Dist.-Paschim Bardhaman under Asansol Municipality Corporation.

This is in reference to your AIN 211912506300003995 dated 11-Feb-2025 regarding Renewal of Fire Safety Certificate for existing construction of G+2 storied Phase-I building, G+3 storied Phase-II building and G+3 storied Phase-III building under group Educational occupancy in the name and style as DAV PUBLIC SCHOOL KANYAPUR ASANSOL at Lions Club Road, PO.-R.K. Mission, Mouza-Gobindpur, Plot No-395, Khatian No-75, J.L. No.-18, PS.-Asansol(N), Pin.-713305, Dist.-Paschim Bardhaman under Asansol Municipality Corporation..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300003995

1. Maintenance/checking testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Department shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire Prevention and Fire Safety Measures.
3. Mock Drill must be performed twice in a year and recorded properly.
4. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
5. No parking will be allowed on the Driveway.
6. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
7. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the buildings shall be strictly maintained.
8. Existing Electrical wiring of the buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
9. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable areas of the site.
10. The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire and Testing.
11. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
12. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
13. First-Aid Fire Fighting system shall be provided as per I.S. specification.
14. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
15. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
16. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
17. The Fire Safety Audit is to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.
18. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled and no renewal would be made.
19. This Renewal of Fire Safety Certificate is valid for three years as per existing Govt. Notification and has to be renewed in due time.

Valid Upto : 27-Mar-2028 Memo No.: FSR/FES/BDN/ 945/2016



Signature valid

Digitally Signed.
Name: RATAN KUMAR HALDER
Date: 29-Mar-2023 10:45:44
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300003995